成品尺寸：540*200mm

Interlinked Smoke and Carbon Monoxide Alarm User Manual

Model: JKD-513COM-R

CE 24 2531

EN 14604:2005/AC:2008
EN 50291-1:2018

EN

Thank you for purchasing this Combination Smoke and Carbon monoxide alarm.
This instruction manual contains important information on starting operation and using the devise. store this manual in a safe place for future reference. the instruction manual is a part of the device – bear this in mind if you pass on this device to others.
Please take a few minutes to thoroughly read the manual and familiarize yourself and your family with its operation.

Table of Contents

1. What to do if the Smoke Alarm Sounds
2. What to do if the CO Alarm Sounds
3. Product Important Information
4. Installation Instructions
5. Understanding your Combo Smoke/CO Alarm
6. General Maintenance
7. Carbon Monoxide Overview
8. Battery Information
9. Product Specifications
10. How to Set up and Interconnect Wireless Alarms
11. Manufacturer Information

1. What to do if the Smoke Alarm Sounds

Smoke alarm pattern is four beeps, repeating every 5 seconds. the Red-Smoke Alarm light flashing, LCD shows fixed value 0.25 and smoke, db/m symbol.
The smoke alarm and CO alarm will circular proceed when both smoke and carbon monoxide are present.
What to do in case of fire.
1. Do not be panic, stay calm.
2. Leave the building as quickly as possible. touch doors to feel if they were hot before opening them. use an alternate exit if necessary. crawl along the floor, and do stop to collect anything.
3. Meet at a pre-arranged meeting place outside the building.
4. Call the fire department form outside the building.
5. Do not go back inside a burning building. wait for the fire department to arrive.

2. What to do if the CO Alarm Sounds

CO alarm pattern is four beeps repeating every 6 seconds. the Red-CO Alarm light flashing, LCD shows real-time concentration value and CO, PPM symbol.
WARNING! –Actuation of your CO alarm indicates the presence of Carbon Monoxide (CO) which can KILL YOU.
WARNING!--Action of this device indicates the presence of dangerous levels of CO! CO can be fatal!
What to do if the alarm sounds:
1. Keep calm and open all doors and windows to increase the rate of ventilation. stop using all fuel- burning appliances and ensure, if possible, that they are turned off, e.g. for gas appliances, isolate the emergency control valve.
2. If the alarm continues to be activated, then evacuate the premises. leave the doors and windows open, and only re-enter the building when the alarm has stopped. In multi-occupancy and multi-storey premises, ensure that all the occupants are alerted to the risk.
3. Get medical help for anyone suffering the effects of carbon monoxide poisoning, and advise that carbon monoxide inhalation is suspected.
4. Telephone the appropriate appliance servicing and/or maintenance agency or, when necessary, the relevant fuel supplier on their emergency number or the national Gas Emergency Service Provider, if appropriate, so that the source of carbon monoxide emissions can be identified and corrected. unless the reason for the alarm is obviously spurious, do not use the fuel-burning appliances again, until they have been checked and cleared for use by a competent person according to national regulations.

If problems are identified during this inspection, have the equipment serviced immediately. note any combustion equipment not inspected by the technician and consult the manufacturer's instructions or contact the manufacturer directly for more information about CO safety and this equipment. make sure that motor vehicles are not or have not been operating in an attached garage or adjacent to the residence.
Never restart the source of a CO problem until it has been corrected.
Never ignore the sound of the CO alarm!

3. Product Important Information

CAUTION! -This Combo Smoke/CO alarm was designed to detect both smoke and carbon monoxide from any source of combustion in a residential environment. It is not designed for use in recreational vehicle (RV) or boat.
CAUTION! -This Combo Smoke/CO alarm was designed for indoor use only. Do not expose to rain or moisture. Do not knock or drop the alarm. Do not open or tamper with the alarm as this could cause malfunction.
CAUTION! -This Combo Smoke/CO alarm is designed to detect carbon monoxide gas from ANY source of combustion. It is NOT designed to detect any other gas.
CAUTION! -This Combo Smoke/CO alarm will not protect against the risk of smoke or carbon monoxide poisoning when the battery has drained.
CAUTION! -Installation of the alarm should not be used as a substitute for proper installation, use and maintenance of fuel burning appliances including appropriate ventilation and exhaust systems.
CAUTION! -This device should be installed by a competent person.
CAUTION! -This Combo Smoke/CO alarm is not intended to alert hearing impaired individuals.
WARNING! - Do NOT try to repair the device, it has the risk of electric shock or malfunction if the device is tampered with.

1. The TEST/SILENCE button accurately tests the device functions. Do not use any other test method. test the device weekly to ensure proper operation.
2. If you're sure it isn't a really alarm, open windows or fan the air around the device for silence it.
3. Observe and follow all local and national electrical and building codes for installation.
4. This Combo Smoke/CO alarm is designed to be used inside a single family only. In multifamily buildings, each individual living unit should have its own smoke alarm devices. Do not install in non-residential buildings. And the device is not a substitute for a complete alarm system.
5. Install a Combo Smoke/CO alarm in every room and on every level of the home. Smoke may not reach the smoke alarm for many reasons. For example, if a fire starts in a remote part of the home, on another level, in a chimney, wall, roof, or on the other side of a closed door, smoke may not reach the device in time to alert household members. This Combo Smoke/CO alarm will not promptly detect a fire or CO dangerous except in the area or room in which it is installed.
6. This Combo Smoke/CO alarm can only sound their alarms when they detect smoke or detect combustion particles or dangerous level of CO in the air. They do not sense heat, flame, or other gas. The device is designed to give audible warning of a developing fire. However, many fires are fast - burning, explosive, or intentional, and others are caused by carelessness or safety hazards. In this circs, Smoke may not remake the unit alarm QUICKLY ENOUGH to ensure safe escape.
7. This Combo Smoke/CO alarm have limitations. The device is not foolproof and is not warranted to protect lives or property from fire. Smoke alarm or/ and CO alarm are not a substitute for insurance. Homeowners and renters should insure their lives and property. In addition, it is possible for the device to fail at any time. For this reason, you must test the device weekly and replace unit every 10 years.


4. Installation Instructions

WARNING! - To prevent injury, this device must be securely attached to the ceiling/wall in accordance with the installation instructions.


4.1 Recommended location for alarms

The following suggestions are intended to help you with the placement and installation of your Combo Smoke and Carbon monoxide alarm.

SINGE FLOOR PLAN




MULTIPLE FLOOR PLAN




● Smoke or smoke/CO alarms for required protection
○ Smoke or smoke/CO alarms for additional protection
△ Smoke alarm with silence control for additional protection


1. Install in a bedroom or hallway located close to the sleeping area. Take special care to verify the alarm can be heard in sleeping areas. If more than one sleeping area exists, locate additional alarms in each sleeping area.
2. Locate a device in every bedroom.
3. It is recommended that a Combo Smoke/CO alarm be installed on each level of a multilevel home.
4. Locate a device in every room where electrical appliances are operated (i.e. portable heaters or humidifiers).
5. Locate 10 feet away from all fuel burning appliances.
6. Placing at eye level allows for optimum monitoring of the red and green indicator lights.
7. Smoke, heat, and combustion products rise to the ceiling and spread horizontally. Mounting the smoke alarm on the ceiling in the center of the room places it closest to all points in the room. Ceiling mounting is preferred in ordinary residential construction.
8. The device should be at least 6 feet (1.8 meters) above the floor level.
9. When mounting a device on the ceiling, locate it at a minimum of 4 inch (10 cm) from the side wall.
10. When mounting the device on the wall, use an inside wall with top edge the alarm at a minimum of 4 inch (10cm) and maximum of 12 inch (30.5cm) below the ceiling.
11. Put the device at both ends of a bedroom hallway or large room if the hallway or room is more than 30 feet (9.1 m) long.
12. Install the device on sloped, peaked or cathedral ceilings at or within 3feet (0.9m) of the highest point (measured horizontally).



4.2 Locations to avoid

For ensure the Combo Smoke/CO Alarm work properly and provide detection performance, do not install the device in the following places:
1. Near appliances or areas where normal combustion regularly occurs (kitchens, near furnaces, hot water heaters). Install at least 10 feet away from these areas. Use specialized smoke alarm device with unwanted alarm control for this areas.
2. In areas with high humidity, like bathrooms or areas near dishwashers or washing machines or directly above a sink. Install at least 10 feet away from these areas.
3. Avoid spraying aerosols near the device.
4. Next to a door or window, an extractor fan, air returns or heating and cooling supply vents. Install at least 3 feet feet away from these areas. The air could blow smoke away from the device, interrupting its alarm.
5. In rooms where temperatures may fall below -10℃ or rise above 55℃, or in humidity higher than 95%. These conditions will reduce battery life or cause a fault alarm.
6. In extremely dusty, dirty, or insect – infested areas influence particles interfere with the device operation.
7. In the garage. Products of combustion are present when you start your automobile.
8. In an enclosed space (for example in a cupboard or behind a curtain).
9. Where it can be obstructed (for example by furniture).
10. Less than 4" (10cm) from the peak of an "A" frame type ceiling.
11. Near fluorescent lights. Electronic "noise" may cause nuisance alarms.
12. Place out of the reach of children. Under no circumstance should children be allowed to handle the device.






4.3 Installation instructions

CAUTION! -This device should be installed by a competent person.
CAUTION! -The alarm MUST be installed on the matching bracket.


When choosing your installation locations, make sure you can hear the alarm from all sleeping areas. If you install only one device in your home, install the device near bedrooms, not in the basement or furnace room.
1. Drilling two ϕ5.0mm holes in the ceiling or wall, the distance between two holes center is 70mm(2.76inch), then inserting two plastic plugs provided into the holes.
2. Attach the bracket to the plastic plugs and fix tightly the screws into the plastic plugs. Do NOT over-tighten screws.
3. Install and rotate the alarm body on the bracket.
4. Test the device by using the TEST/SILENCE button. Ensure the device sound is alarm pattern.

As you install the device, it maybe will sound for several minutes, then stop and enter in normal operation mode. If it always sounds, please call our agent.



4.4 Un-installation instructions

Rotate clockwise for installation
Rotate counter clockwise for un-installation




un-installation installation

CAUTION! -This Combo Smoke/CO alarm MUST be installed on the matching bracket.

5. Understanding your Combo Smoke/CO Alarm

5.1 Product overview



1. POWER indicator(green)
The green indicator is used to indicate power status of the device. The green indicator will flash every 40 seconds.
2. FAULT indicator(yellow)
The yellow indicator is used to indicate malfunctions or low battery warning status of the device.
3. ALARM indicator (red)
The red indicator is used to indicate alarm status of the smoke alarm or CO alarm.
4. TEST/SILENCE button
The TEST/SILENCE button is used to test the device and to silence the unit during a smoke alarm. Press and hold to enable TEST function, Or press to enable SILENCE function.
5. Sounder
The sounder is used to send out smoke alarm, CO alarm warning and abnormal warning information.

5.2 Operation and testing

1. **Start up**
After connecting the battery, three color indicators (green/yellow/red) will light up briefly and the device confirms start-up with a beep, enters into the preheating countdown.
After power on, 90 seconds before the POWER indicator (green) flash every 2 seconds, this is preheated state, 90 seconds later the POWER indictor(green) flashing every 40 seconds indicates the device is functioning properly.
2. **Normal operation**
The POWER indicator(green) flashing every 40 seconds.
3. **Fault warning**
If the device chirps twice every 40 seconds, with Yellow-Fault flashs, and LCD display "Err". It indicates the device is in sensor malfunction condition. that means your device has no detecting feature and no respond to smoke or CO.
CAUTION! -When Fault warning occur, replace the device immediately. Please contact us to more service.
4. **Low battery voltage warning**
If the device chirps once every 40 seconds, with FAULT indictor (yellow) will be flash. It indicates the battery is low.
NOTE: When the low battery voltage warning is occur, the device has capable of producing a smoke alarm signal or CO alarm signal for at least 4 min or 30 days of low battery voltage warning signal operation.
WARNING! You need to replace the battery as possible as soon when the device enters this status.
WARNING! The device will not protect against the risk of smoke and carbon monoxide poisoning when the battery has drained.
5. **Smoke alarm**
When the device detects a dangerous level of smoke, the device will emit a smoke alarm pattern. The smoke alarm signal pattern is 4 beeps followed by 1 seconds of silence. This cycle repeats as long as a dangerous smoke condition exists. The Red-Smoke Alarm light will flashing the same pattern. This signal will repeated until dissipation of smoke or the alarm signal is manually silenced.
CAUTION! -Refer to "1. What to do if the smoke alarm sounds" when you hear the sounds of the smoke alarm warning.
DANGER! -If the alarm sounds, and it is not being tested, it means the unit is sensing SMOKE/CO, THE SOUND OF THE ALARM REQUIRES YOUR IMMEDIATE ATTENTION AND ACTION.
6. **Smoke alarm silence**
During the device under smoke alarm mode, push the TEST/SILENCE button, it will be paused the device alarm sound for approx 10 minutes. The ALARM indictor(red) will keep flash as smoke alarm mode, it indicates the device is running into the smoke alarm silence mode. This Combo Smoke/CO alarm is designed to minimize nuisance alarms. Combustion particles from cooking may set off the alarm if the alarm is located close to the cooking area. Large quantities of combustible particles are generated from spills or when grilling/ frying. Using the fan on a range hood that vents to outside (non-recirculating type) will also help remove these combustible particles from the kitchen. The smoke alarm silence (TEST/SILENCE button) is extremely useful in a kitchen area or other areas prone to nuisance alarms. The silence feature is to be used only when a known alarm condition, such as smoke from cooking activates the alarm. The device is desensitized by pressing the TEST/SILENCE button on the smoke alarm cover, the device will silence to indicate that the device is in a temporarily desensitized condition.
The Combo Smoke/CO alarm will automatically reset after approx 10 minutes, if after this period, particles of combustion are still present, the alarm will sound again.
The smoke alarm silence (smoke alarm silence mode) can be repeatedly until the air has been cleared of the condition causing the alarm.
CAUTION! -Before using the smoke alarm silence (silence), identify the source of the smoke and be certain a safe condition exists.
7. **CO alarm**
When the device detects a dangerous level of CO, the device will emit a loud alarm pattern. The alarm signal pattern is 4 beeps followed by 2 seconds of silence. This cycle repeats as long as a dangerous CO condition exists. The Red-CO Alarm will flashing the same pattern.
This signal will repeated until dissipation of CO.
CO alarm sensitivity Setting:

Conforms to EN50291-1:2018
50PPM Between 60 to 90 minutes
100PPM Between 10 to 40 minutes
300PPM Less than 3 minutes

If the CO concentration detected exceed 20PPM and no more than alarm setting concentration, the LCD shows real-time concentration value and CO, PPM symbol, the device will not alarm.
NOTE: The Smoke alarm and CO alarm will circular proceed when both smoke and carbon monoxide are present, and the LCD will switch the display once for 1s, alternately displaying the CO alarm and the SMOKE alarm.
CAUTION! -Refer to "2. What to do if the CO alarm sounds" when you hear the sounds of the CO alarm warning.
8. **Test the device**
To test the device, pressing TEST/SILENCE button, you should heard alarm sound patterns and with a corresponding ALARM indicator(red) flashes.
NOTE: After the TEST/SILENCE button is enabled, the alarm sounds and the red alarm light flashes. This does not indicate that CO is present.
NOTE: Test the unit weekly! If at any time your unit does not perform as described, replace it immediately.
WARNING! -Do NOT use an open flame to test your alarm, it could damage the alarm or ignite combustible materials and start a structure fire.
WARNING! -Due to the loudness (85 decibels) of the alarm, Always stand an arms-length away from the unit when testing.
9. **End of life warning**
The sensor max life is 10 years, when the life of the sensor ends, it will have a prompt, the buzzer sounds 3 times, yellow indicator flashes 3 times at the same time per 50 seconds, and LCD display "End". it indicates this Combo alarm is in end of life. That means your device has no detecting feature and no respond to smoke and CO. Please change a new detector.
NOTE: You need to replace the device as soon as possible when the device enters this status.

5.3 Trouble shooting

CAUTION! -Do not attempt to repair the device. It will affect your warranty. If the device is not operating properly, and is still under warranty, return it to the original place you buy. Pack it in a well-padded carton, and ship to the original place you buy.
If the alarm is no longer under warranty, have a licensed electrician replace it immediately with a comparable alarm.

Tabel 5.3 Trouble shooting guide:

Problem	Method of disposal
The device does not sound when press TEST/SILENCE button	1. The device is power off. 2. The device is under "Smoke alarm silence" or " Low battery voltage warning silence" or "Fault warning" mode. Please ensure the device is under "Normal operation" mode then test the device. 3. Clean the device. Please refer to the "6. General maintenance". 4. If there are still failures during warranty, you can return it to your retailer. 5. If the unit is out of warranty, please replace another new device.
The device chirps once with FAULT indicator (yellow) flashes once every 40 seconds	LOW BATTERY VOLTAGE SIGNAL. The battery is under low battery status, please replace the battery.
The device chirps twice with FAULT indicator(yellow) flashes twice every 40 seconds	MALFUNCTION SIGNAL. Clean this device. Please refer to the "6. General maintenance ". 1.If the device under warranty, please return it to your retailer for replacement. 2.If the device is out of warranty, please replace another new device.
The device sounds unwanted alarms when residents are cooking, taking showers, etc.	1.Press TEST/SILENCE button to pause alarm. 2.Clean the smoke around the device.

6. General Maintenance

To keep your Combo Smoke/CO alarm in good working order, please follow these simple steps:
1. Verify the unit's alarm sound and indictors operation by enable the TEST/SILENCE button once a week.
2. Remove the unit from the ceiling and clean the alarm cover and vents with a soft brush attachment once a month to remove dust and dirt.
3. Never use detergents or other solvents to clean the unit.
4. Avoid spraying air fresheners, hair spray, or other aerosols near the device.
5. Do not paint the device. Paint will seal the vents and interfere with the sensor's ability to detect CO. Never attempt to disassemble the unit or clean inside. This action will void your warranty.
6. As soon as possible, place the Combo Smoke/CO alarm back in its proper location to assure continuous protection from fire and carbon monoxide poisoning.
7. When household cleaning supplies or similar contaminants are used, the area should be ventilated.
WARNING! -The following substances can affect the sensor and may cause false actions: methane, propane, isobutene, isopropanol, ethylene, benzene, toluene, ethyl acetate, hydrogen sulfide, sulfur dioxides, alcohol based products, paints, thinner, solvents, adhesives, hair sprays, after shaves, perfumes and some cleaning agents.
WARNING! -Your Combo Smoke/CO alarm will not be operational and will not monitor for smoke and CO levels without battery.
WARNING! -This apparatus is designed to protect individuals from the acute effects of carbon monoxide exposure. It may not however, prevent the chronic effects of carbon monoxide exposure and will not fully safeguard individuals at special risk or with specific medical conditions. If in doubt consult a medical practitioner.

7. Carbon Monoxide (CO) Overview

Carbon monoxide (CO) is a highly poisonous gas that has no taste, colour or smell and therefore very difficult to detect with the human sense. CO kills hundreds of people each year and injuries many more. It binds to the hemoglobin in the blood and reduces the amount of oxygen being circulated in the body. In high concentration, CO can kill in minutes. CO is produced from poorly burning appliances, such as:
• Wood-burning stoves
• Gas boilers and Gas heater
• Oil and coal burning appliances
• Blocked flues and chimneys
• Waste gas from car garages
• Barbecues

Symptoms Indicated by Carbon Monoxide Concentration Poisoning

CO Concentration	Rough inhalation time and symptoms developed
50ppm	Maximum concentration bearable in 8 hours for healthy adults
200ppm	Light headache, weak, dim eyesight and nausea after 2-3 hours
400ppm	Forehead pain in 1-2 hours, threaten life after 3 hours
800ppm	Dim eyesight, nausea and spasm in 45 minutes, lose consciousness in 2 hours, death in 2-3 hours
1600ppm	Headache, dim eyesight and nausea in 20 minutes, death in 1 hour
3200ppm	Headache, dim eyesight and nausea in 5-10 minutes, death in 25-30 minutes
6400ppm	Headache, dim eyesight and nausea in 1-2 minutes, death in 10-15 minutes
12800ppm	Death in 1-3 minutes

8. Battery Information

8.1 **Battery type**
This device is powered by 2pcs Exnnall 1.5V AA alkaline battery. the battery type is LR6.
Once activated, the battery will supply power to the alarm for 3 years under normal operation conditions.
NOTE: Battery installation or replacement is necessary for the life of the device.
NOTE: Constant exposure to high or low humidity may reduce battery life.

8.2 **Battery replacement**
Rotate counter clockwise the alarm and take down it from mounting bracket, open the battery compartment cover, take out the spent batteries, install the new batteries with the correct positive and negative electrodes, check whether the device is powered on, then close the battery cover and install the alarm on mounting bracket.

8.3 **Battery disposal**
WARNING!-Fire, explosion, and severe burn hazard. Do not recharge, crush disassemble, heat above 100℃, incinerate or expose contents to water.
1.Not to dispose of battery (or the device) as unsorted municipal waste, but collect it separately.
2.Dispose of in accordance with all applicable federal, state and local regulations.

9. Product Specifications

Model: JKD-513COM-R
Software version number: V1.2.5
Communication protocol: RF433MHz
Frequency and max power: 433.92 MHz @ -14.96 dBm
Transmission Range: over 100m in open area
Product standards: EN 14604:2005/AC:2008
EN 50291-1:2018
Type of apparatus: type B - to provide a visual and audible alarm only
Power Supply: 2pcs 1.5V AA battery
Sensor of Smoke: Photoelectric reflection
Smoke Alarm Sensitivity: 0.25dB/m
Smoke alarm silence: about 10 minutes
Sensor of CO: Electrochemical
CO alarm sensitivity Setting:
Conforms to EN50291-1:2018
50PPM alarm within 60 to 90 minutes
100PPM alarm within 10 to 40 minutes
300PPM alarm within 3 minutes
Product life: 10 years after manufacture
Standby Current: <50μA (average)
Alarm Current: <90mA (average)
Operation Ambient Condition: -10℃~+50℃, ＜95%RH non-condensing
Storage/Transport Condition: -10℃~+50℃, ＜95%RH non-condensing
Alarm sound : ≥85dB at 3m
Installation Location: ceiling or wall
Detection range: Max. 40m² within a room.
Size: about Φ105*39mm
Weight: 180±10g (net)

10. How to Set up and Interconnect Wireless Alarms

All JIKAIDA wireless interlinked alarms contain a built-in RF module that enables you to wirelessly connect 2 or more interlinked alarms and create an interlinked network. when one unit is triggered, all interconnected alarms will sound.
The JIKAIDA series contain wireless interlinked smoke alarms, wireless interlinked carbon monoxide alarms, wireless interlinked gas alarms, wireless interlinked combination smoke and carbon monoxide alarms, and wireless interlinked combination gas and carbon monoxide alarms.
This model is designed to be wirelessly interlinked with other JIKAIDA alarms, but is not designed to communicate with wireless interlinked alarms from other manufactures.

10.1 How to create the interlinked network

Step 1: Quickly press the TEST button 5 times on one of these alarms, the green light flashes rapidly, the LCD shows rF2 and the backlight is on, indicating it has enter the transmitting mode (valid time: 120 seconds, in this state, hold down the button for 5 seconds to exit transmitting mode, Otherwise, the system automatically exits this mode after 120 seconds).
Step 2: Press the TEST button 3 times on the other alarms, the green light flashes rapidly, the LCD shows rF1 and the backlight on, indicating it has enter the receiving mode.
------If pairing is successful: the green LED of these alarms will stop flashing, and the buzzer "beep" one time.
------When it is failure, the green LED will continue to flash for 120 seconds, and then exit the code learning mode.
If you want to connect more units to this group, simply repeat step 1 and step 2.
After all units done interconnected and enter in standby mode, test the alarms according to the steps in the section "Interconnected Alarm Test".

10.2 How to Disconnect the Alarms

Press the TEST button 3 times on the alarms, the green light flashes rapidly, then hold down the button(approx. 5 seconds) until it beeps once to disconnect. After disconnecting, it can be reconnected to the same network, or added to a new network.

NOTES
1. A maximum of 30 alarms can be interconnected together.
2. Test all wireless alarms to ensure they are interconnected before installation.
3. The model can only be interconnected with other JIKAIDA wireless interlinked alarms.

10.3 Interconnected Alarm Test

If your device is interconnected to other wireless alarms, we recommend that every individual alarm is tested during the weekly test.
Press the test/silence button, the initiating alarm will beep 4 times with LED flashing. other interconnected alarms in the network will receive the signal and beep continuously with the LED flashing. After testing, the alarms will automatically enter standby mode.

10.4 Interconnected Silence Mode

If you press the silence button during an alarm state, the unit will be in the silence mode for 10 minutes. During the silence mode, the LED will flash continuously. the alarms will enter the normal mode after 10 minutes.

NOTES
1. You can silence all interconnected units by pressing the test/silence button on one of the alarms. If one units is still alarming, it is the initiating alarm (the unit that detected the target object), to silence all connected units, you must also press the test/silence button on the initiating alarm.
2. In the interconnected mode, the initiating alarm cannot be triggered again during the silence duration,However, all other interconnected alarms will be temporarily silenced and enter standby mode, and will alert again if they detected dangerous target levels.
3. If the CO concentration is above 300ppm, the silence function cannot be enabled.

11. Manufacturer Information:

Company Name: ShenZhen Jikaida Technology Co., Ltd
Add: 201, Buiding 7, ChuangYe Industrial Park, ShaPuWei Community, Songgang Street, Bao'an District, ShenZhen, China
Tel: +86 0755 81736697